

ಶ್ರೀ ಎಚ್. ಎನ್. ನಂಜೇಗೌಡ.—ಆ ವಿವರಗಳನ್ನು ಡೇಟ್‌ವಾರ್ ಹೇಳಬೇಕಾದರೆ ಬೇರೆ ಪ್ರಶ್ನೆ ಹಾಕಿದರೆ ಹೇಳುತ್ತೇನೆ.

ಶ್ರೀ ಎಸ್. ಬಂಗಾರಪ್ಪ.—ತಾಂತ್ರಿಕ ಮಂಜೂರಾತಿಯನ್ನು ಸಿ.ಡಬ್ಲ್ಯು.ಪಿ.ಸಿ. ಯವರು ಕೊಟ್ಟಿರುವುದರಿಂದ, ಕೇಂದ್ರ ಸರ್ಕಾರದಿಂದ ಎಷ್ಟು ಹಣದ ಸಹಾಯ ನಮ್ಮ ರಾಜ್ಯಕ್ಕೆ ಸಿಕ್ಕಿದೆ ?

ಶ್ರೀ ಎಚ್. ಎನ್. ನಂಜೇಗೌಡ.—ಕ್ಲಿಯರೆನ್ಸ್ ಕೊಡುವುದಕ್ಕೂ, ನಮಗೆ ಹಣಕಾಸಿನ ಸಹಾಯ ಮಾಡುವುದಕ್ಕೂ ಬಂದಕ್ಕೊಂದು ಸಂಬಂಧವಿಲ್ಲ ಎಂದು ಪದೇ ಪದೇ ಈ ಸಭೆಯಲ್ಲಿ ಹೇಳಿದ್ದೇವೆ.

ಶ್ರೀ ಎಚ್. ಎಸ್. ಸಿದ್ದಪ್ಪ —ಈ ಪ್ರಾಜೆಕ್ಟ್‌ನಲ್ಲಿ ಯಂಗಳಿ ಸೇರಿಸಿ ಅದನ್ನೂ ಪರ್ಸೂ ಮಾಡುತ್ತೀರಾ ?

ಶ್ರೀ ಎಚ್. ಎನ್. ನಂಜೇಗೌಡ.—ಯಂಗಳಿ ಬಗ್ಗೆ ಕ್ಲಿಯರೆನ್ಸ್ ಸದ್ಯದಲ್ಲಿಯೇ ಸಿಕ್ಕುತ್ತದೆ ಎಂದು ನಿರೀಕ್ಷೆ ಮಾಡುತ್ತಿದ್ದೇವೆ.

ಶ್ರೀ ಎಸ್. ಬಂಗಾರಪ್ಪ.—ತಾಂತ್ರಿಕ ಮಂಜೂರಾತಿ ಪಡೆಯತಕ್ಕ ವಿಷಯದಲ್ಲಿ ಪತ್ರ ವ್ಯವಹಾರ ನಡೆಯುತ್ತಿದೆ ಎಂದು ತಿಳಿಸಿದ್ದಾರೆ. ಈಗ ಆ ವ್ಯವಹಾರ ಯಾವ ಹಂತದಲ್ಲಿದೆ ; ಇನ್ನು ಎಷ್ಟು ದಿವಸದಲ್ಲಿ ಮಂಜೂರಾತಿ ಸಿಕ್ಕುತ್ತದೆ ಅಥವಾ ಇಲ್ಲ ಎನ್ನುವ ಫೈನಲ್ ಡಿಸಿಷನನ್ನು ಕೇಂದ್ರ ಸರ್ಕಾರದಿಂದ ಪಡೆಯುವುದಕ್ಕೆ ಸಾಧ್ಯವಾಗುತ್ತದೆ ?

ಶ್ರೀ ಎಚ್. ಎನ್. ನಂಜೇಗೌಡ.—ಬೇಗ ಸಿಕ್ಕಲಿ ಎಂದು ನಿರೀಕ್ಷೆ ಮಾಡುತ್ತೇವೆ. ಯಾವಾಗ ಎನ್ನವುದನ್ನು ಕೇಂದ್ರ ಸರ್ಕಾರ ಹೇಳಬೇಕಾಗುತ್ತದೆ.

## SUPPLY OF ELECTRICITY TO COORG DISTRICT

845. SRI A. M. BELLIPPA (Mercara).—Will the Minister for Public Works and Electricity be pleased to state :—

- (a) the number of K. Ws. of power released to Coorg District ;  
the number of applications pending for supply of electricity ;
- (b) whether it has come to the notice of Government that power supply fails frequently during peak hours ;
- (c) if so, the reasons for the same and the number of interruptions in the month of May 1972 at Virajpet, Somwarpet, Mercara and Gonicoppal ;
- (d) if so, the reasons for not increasing the capacity of the load to District ?

SRI H. M. CHANNABASAPPA (Minister for Public Works and Electricity).—

- (a) (i) 4690 KVA against the installed capacity of 10,000 KVA.  
(ii) 30 as on 30-6-1972.
- (b) Occasionally.

(Sri H. M. Channabasappa)

- (c) The interruptions are mainly due to falling of trees on the lines which pass through thick Jungles due to heavy velocity winds during the period.

8 times totalling to 29 minutes in Virajpet area.

36 times totalling to 38 hours 26 minutes in Somwarpet area.

17 times totalling to 7 hours 38 minutes in Mercara area.

22 times totalling to 15 hours 3 minutes in Gonikoppal area.

- (d) Sub-stations in the area have got sufficient capacity to cater to the growing demands and the question of increasing the capacity does not arise.

SRI A. M. BELLIPPA.—How many installations are there in Coorg District and how many stations and sub-stations are proposed to be constructed ?

† SRI H. M. CHANNABASAPPA.—There are already sub-stations at Kushalnagar, Virajpet and Gonikoppal and some others are proposed to be constructed.

SRI A. M. BELLIPPA.—How many power installations are there in Coorg District ?

SRI H. M. CHANNABASAPPA.—I cannot answer the question as it is not clear.

SRI A. M. BELLIPPA.—On account of difficult terrain there are so many interruptions. Will Government therefore think of having a separate division ?

SRI H. M. CHANNABASAPPA.—Formation of a separate Division is not going to solve the difficulties. The terrain of the country is such that some of these difficulties are inevitable and a separate Division is not going to help in removing these difficulties.

ಶ್ರೀ ಆರ್. ಗೊಂಡೂರಾವ್.—ಕೊಡಗಿನಲ್ಲಿ ಬಹಳ ಜಾಸ್ತಿ ಕಾಡು ಇರುವ ದೆಸೆಯಿಂದ ಆಗಾಗ್ಗೆ ಎಲೆಕ್ಟ್ರಿಸಿಟಿ ಕೆಟ್ಟು ಹೋಗುವ ದೆಸೆಯಿಂದ, ವಿಶೇಷವಾದ ಕಾರ್ಯಕ್ರಮ ಕೈಗೊಳ್ಳುತ್ತೀರಾ?

ಶ್ರೀ ವಿಜ್ಞಾನಿ ಎಂ. ಚನ್ನಬಸಪ್ಪ.—ಎಷ್ಟೆಷ್ಟು ಗಂಟೆ ಯಾವ ಯಾವ ಕಾಲದಲ್ಲಿ ಆಗಿದೆ ಎನ್ನುವುದನ್ನು ಉತ್ತರದಲ್ಲಿ ಕೊಟ್ಟಿದ್ದೇನೆ. ಸ್ವಾಭಾವಿಕವಾಗಿ ಗಾಳಿ ಮಳೆ ಹೆಚ್ಚು ಎದ್ದಾಗ ಕಾಡು ಮೇಡುನಲ್ಲಿ ಇರತಕ್ಕ ಲೈನ್ ಗೆ ತೊಂದರೆಗಳು ಉಂಟಾಗತಕ್ಕದ್ದು ಸ್ವಾಭಾವಿಕ. ಅದನ್ನು ಎಷ್ಟು ಕಡಿಮೆ ಮಾಡುವುದಕ್ಕೆ ಸಾಧ್ಯವೋ ಅಷ್ಟು ಕಡಿಮೆ ಮಾಡಲಿಕ್ಕೆ ಎಲ್ಲಾ ವಿಚಾರಣೆ ನಡೆಸಿ ತೊಂದರೆಯಾಗದಂತೆ ನೋಡಿಕೊಳ್ಳುವ ವ್ಯವಸ್ಥೆ ಮಾಡುತ್ತೇನೆ.